



FOURTH FLOOR

EXISTING ITEMS	
[FB]	Fire Blanket
[VP]	Vision Panel
[DC]	Door Closer
[HR]	Hose Reel
[CSD]	Cells Smoke Detection Control Panel
[FAP]	Fire Alarm Panel
[FARP]	Fire Alarm Repeater Panel
[IS]	Intumescent Strip / Smoke Seals
[DS]	Direction Sign
[FAS]	Fire Action Sign
[FDS]	Fire Door Sign
[Ex]	Exit Sign
[Ex(M)]	Exit Sign Maintained Luminaire
[Ex(NM)]	Exit Sign Non-Maintained Luminaire
[NM]	Non Maintained Luminaire
[M]	Maintained Luminaire
[○]	Break Glass Contact
[●]	Heat / Smoke Detector
[🔔]	Bell / Electronic Fire Sounder
[🔥]	Water Filled Fire Extinguisher
[🔥]	Foam Filled Fire Extinguisher
[🔥]	Carbon Dioxide Filled Fire Extinguisher
[🔥]	Powder Filled Fire Extinguisher
[SP]	Sprinkler Head
[🔔]	Beacon
[🔓]	Magnetic Door Release Unit

NOTES	
1.	DO NOT SCALE DIMENSIONS OFF THIS DRAWING
2.	THE POSITIONS OF EQUIPMENT SHOWN ON THIS DRAWING ARE INDICATIVE OF THEIR APPROXIMATE POSITION ON SITE. THIS DRAWING SHOULD BE USED FOR GUIDANCE PURPOSES ONLY.
3.	FDS x 2 INDICATES A FIRE DOOR SIGN ON EACH FACE OF THE DOOR.
4.	<b>ILMCS AREAS</b>
	■ Compartment 1
	■ Compartment 2
	■ Compartment 3
	■ Compartment 4
	■ Compartment 5
	■ Probation Area
	■ Stairwell
	■ Cells
	■ Gaolers
	■ Photoluminescent proposed direction signs
	■ Photoluminescent proposed exit signs
	■ Proposed Menvier non maintained luminaire with direction legend or exit legend
	■ Proposed Fluorel non maintained luminaire with direction legend or exit legend
	■ Proposed FD30's single leaf
	■ Proposed FD30's double leaf

**PLEASE TAKE NOTE OF THE**  
**This drawing is an integral part of a sp**  
**The layers used in the space analysis system**  
**be included in this drawi**  
**Area, Boxes, SJJ, Split Hatch :**  
 Do not **REMOVE** any of the  
 Do not **DELETE** any item from  
 Do not **MOVE** any item between  
 Before this plan is returned **EACH**  
 must have its current use entered with  
 Please read the Drawing Protocols which were  
 Thank you for your co-op

**AQUMEN**  
The Facilities People

**ROUGHTON**  
Victoria Station House, 191 Victoria Street, London, SW1E 5NE  
Tel: 020 7932 2800 Fax: 020 7630 8477 E-mail: london@roughton.co.uk

PROJECT  
INNER LONDON  
MAGISTRATES COURT

PROJECT LOCATION  
CAMBERWELL  
MAGISTRATES COURT

DRAWING TITLE  
FOURTH FLOOR EXISTING/  
PROPOSED NEW WORKS  
FIRE PROTECTION SCHEDULE

PROJECT No	SL5018	SCALE	N.T.S
APPROVED	P.M	SURVEYED	O.K
DATE	SEPTEMBER	DRAWN	AD/R.W

BUILDING SERVICES

DRAWING No	REVISION
CA(E)3106	

P:\ACAD12\SL5018\SHEETS\CAMBERWELL\CA(E)3106.DWG